# Utah Department of Environmental Quality Division of Drinking Water

# Public Water System Inventory Report

Run Date: 08/04/2011 01:12 pm

PWS ID: UTAH29024 Name: LAKEVIEW WATER COMPANY

Legal Contact LAKEVIEW WATER CO. Rating: Approved

JAMES BERNARD BANKS Rating Date: 05/23/1989

Address: PO BOX 314 Activity Status: Active

HUNTSVILLE, UT 84317

Phone Number: 801-745-3856

City Served (Area):

County: WEBER COUNTY

Gal/Day Gal/Min

System Type: Community

Last Inv Update: 12/17/2009

Activity Status Cd: Active

Last Snty Srv Dt: 10/20/2009

Total Dsgn Cap:

Surveyor: KELLY HOLMES

Total Emerg Cap:

Oper Period: 1/1 to 12/31

**Contacts** 

Contact		Phone Numbers							
Type	Name	Title	Office	Emergency	Email Address				
AC	BANKS, JAMES BERNARD		801-745-3435	801-745-3856	banksbackhoe@msn.com				

#### **Service Connections**

Connection			Number	
Type	Meter Type Code	Meter Size	Connections	
Residential	Metered	0	43	
			43 To	· otal Svc Connections

### Storage

Total Storage: 1,029,000 GAI Number of Units: 3 Adequate Capacity: NO

No.	Name	Туре	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	RESERVOIR #1	Ground	80,000 GAL	Concrete		Α	
ST002	RESERVOIR #2	Ground	500,000 GAL	Concrete		Α	
ST003	RESERVOIR #3	Reservoir	449,000			Α	

## **Distribution System**

Pump Type	Total Dyn Head	Pressure	Cross	Auhority
	ft H2O P.S.I.	Adequate	Connection	Statement
		No		

#### **Sources**

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	MITCHELL WELL (EAST WE	El Active	WL	8	163 GPM	120 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS002	PETERSON WELL (WEST V	V Active	WL	10	60 GPM	70 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS003	WELL #3	Inactive	WL				Yes	GW	Other		

<sup>\*</sup>Reports measured flow for wells, approved design capacity for all other sources.